

PUBLIC WORKS DEPARTMENT (B & R), HARYANA



Office of the Executive Engineer,  
Provincial Division, PWD B&R Br., Faridabad  
Tele - 0129-2288187  
Email ID: pwd-eepd1-faridabad@hry.nic.in



Memo No. 2658

Dated 13/04/2023

To

The Principal,  
Shanti Niketan Public School,  
Sector-21A,  
Near Badkhal Flyover, Faridabad.

**Subject:- NOC for Building Structure Stability Safety Certificate for Shanti Niketan Public School, Sector-21A, Near Badkhal Flyover, Faridabad.**

**Reference:-** Your office endst No.SPS/OFF/174/2023-24 dated 10.04.2023.

In the connection of above cited subject, it is submitted that the above said school building is inspected by Sh. Siddharth Dev, Junior Engineer of this office on 12.04.2023. The school building having ground floor, first floor & second floor. Following are the features of the building observed during the inspection of the school:-

**GROUND FLOOR:-**

- At ground floor there are 12 no. Classrooms, 1 no. Principal room with attached Rest room & Toilet, 2 no. Office, 1 no. Reception, 2 no. Staff room with attached toilets, 2 no. Boys Toilets, 2 no. Girls Toilets, all around passage, 1 no. Staircase & 1 no. Ramp are exist in the school premises.

**FIRST FLOOR:-**

- At first floor there are 13 no. classrooms, 2 no. Office, 1 no. Staff room with attached toilet, 2 no. Boys Toilets, 2 no. Girls Toilets, all around passage, 1 no. Staircase & 1 no. Ramp are exist in the school premises.


## SECOND FLOOR:-

- At second floor there are 13 no. classrooms, 2 no. Office, 1 no. Staff room with attached toilet, 2 no. Boys Toilets, 2 no. Girls Toilets, all around passage, 1 no. Staircase & 1 no. Ramp are exist in the school premises.

The building is constructed with frame structure having RCC beams slab and 9" thick load bearing outer walls. The structure stability certificate has been also enclosed, which is issued by R.S. Yadav & Associates Chamber No.61, Typist Block, Civil Side, Tis Hazari Court, Delhi dated 12.04.2023. The fire NOC has been issued by the Assistance Divisional Fire Officer/Fire Station Officer, Fire Station Sector-15, Faridabad Memo No.FS/2022/305 dated 09.05.2022 valid upto 08.05.2023. The hygiene certificate was also issued by O/o Civil Surgeon, Faridabad vide their office No.HHC/FBD/2022/000111 dated 29.04.2022 valid upto 31.03.2023 and now application for renewal of the certificate is under process.

Keeping in view all the circumstances and the documents submitted by the applicant, the building is seems to be safe. The building safety certificate has been issued to the above mentioned school for the time period of one year. The periodical inspection of the school building must be ensured.

DA/Nil


  
Executive Engineer,  
Provincial Division,  
PWD B&R Br., Faridabad

Endst. No.

Dated:

Copy of above is forwarded to Sub Divisional Engineer, Provincial Sub Division No.3, PWD B&R Br Faridabad w.r.t. your office memo No.514 dated 12.04.2023 for information

DA/Nil

  
Executive Engineer,  
Provincial Division,  
PWD B&R Br., Faridabad

## BUILDING SAFETY CERTIFICATE

No. 2658


Dated: 13/04/2023

Certified that the existing building Shanti Niketan Public School (name of the building or premises) at Sector - 21A, Faridabad, Haryana (address) comprised of N.A basement(s) and G + 1<sup>st</sup> + 2<sup>nd</sup> (upper floors) owned/occupied by Shanti Niketan Public School (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of PWD B&R Br. (Name of Department/ Govt.) on 12.04.2023 (date of inspection) in the presence of (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes (X/ XII) with effect from 13/04/2023 for a period of One (01) years in accordance with rule and subject to compliance of the specific conditions as appended.

- 1.
- 2.
- 3.
- 4.

Issued on 13.04.2023 at ..... by

\* Strike out whichever is not applicable.

Signature with Seal :   
 Executive Engineer  
 Provincial Division  
 PWD B&R Br. Faridabad  
 Name : Pardeep Singh  
 Designation : Executive Engineer  
 Name & Address of Department/ Office: PD PWD B&R Br.  
 (Assistant Engineer & above officer of concerned Govt. Department only) Faridabad

**Note:** This certificate should be signed / issued by Assistant Engineer & above officer of concerned Govt. Department only

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.