



**PUBLIC WORKS DEPARTMENT (B & R), HARYANA**

Office of Executive Engineer,  
Provincial Division,  
PWD B&R Br., Faridabad.  
Tele – 0129-2288187



[pwd-eepd1-faridabad@hry.nic.in](mailto:pwd-eepd1-faridabad@hry.nic.in)

**Memo No.**

3009

**Dated**

3/6/2024

To

The Principal,  
Shanti Niketan Public School,  
Sector-21 A Near Badkhal Flyover,  
Faridabad.

**Subject:-** NOC for building structure stability safety certificate for Shanti Niketan Public School, Sector-21A Near Badkhal Flyover, Faridabad.  
**Reference:-** Your letter no. SPS/183/off/2024-25 dated 03.05.2024

In the connection of above cited subject, it is submitted that the above said school building is inspected by Sub Divisional Engineer, Provincial Sub Division No.3 PWD B&R Br., Faridabad along with concern Junior Engineer on 30.05.2024. The school building having ground floor, first floor & second floor. The inspection fees of site is deposited by the applicant vide GRN No.0117053775 dated 27.05.2023. Following are the features of the building observed during the inspection of the school:-

**GROUND FLOOR:-**

➤ At ground floor there are 12 no. Classrooms, 1 no. Principal room with attached Rest room & Toilet, 2 no. Office, 1 no. Reception, 2 no. Staff room with attached toilets, 2 no. Boys Toilets, 2 no. Girls Toilets, all around passage, 1 no. Staircase & 1 no. Ramp are exist at the ground floor level.

**FIRST FLOOR:-**

➤ At first floor there are 13 no. classrooms, 2 no. Office, 1 no. Staff room with attached toilet, 2 no. Boys Toilets, 2 no. Girls Toilets, all around passage, 1 no. Staircase & 1 no. Ramp are exist at the first floor level.

**SECOND FLOOR:-**

➤ At second floor there are 13 no. classrooms, 2 no. Office, 1 no. Staff room with attached toilet, 2 no. Boys Toilets, 2 no. Girls Toilets, all around passage, 1 no. Staircase & 1 no. Ramp are exist at the second floor level.

The building is constructed with frame structure having RCC beams slab and 9" thick load bearing outer walls. The structure stability certificate has been also enclosed, which is issued by R.S. Yadav


& Associates Chamber No.61, Typist Block, Civil Side, Tis Hazari Court, Delhi dated 12.04.2023. The fire NOC has been issued by the Assistance Divisional Fire Officer/Fire Station Officer, Fire Station Sector-15, Faridabad Memo No.FS/2023/470 dated 25.05.2023 valid upto 24.05.2026. The hygiene certificate is also issued by O/o Civil Surgeon, Faridabad vide their office No.HHC/FBD/2024-25/54 dated 01.05.2024 valid upto 31.03.2025.

Keeping in view all the circumstances and the documents submitted by the applicant, the building is seems to be safe. The building safety certificate may be issued to the above mentioned school for the time period of one year. The periodical inspection of the school building must be ensured.

DA/Nil


Endst.No.

Dated:-

  
Executive Engineer,  
Provincial Division,  
PWD B&R Br Faridabad.

Copy of above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.3, PWD B&R Br., Faridabad for information and necessary action with reference to his office Memo No. 1151 dated 30.05.2024.

DA/Nil

  
Executive Engineer,  
Provincial Division,  
PWD B&R Br., Faridabad